

Gas Service/Breakdown Record

Certificate Ref.

11 Steeping Road Rugby CV23 9SS

Certificate No 11 Steeping Road Rugby

Installation Details

Installation Address: Kevin McLoughlin
11 Steeping Road
Rugby

Postcode: CV239SS

Client Details

Client Address: Kevin McLoughlin
11 Steeping Road
Rugby

Postcode: CV239SS

Appliance Details

CO/CO2 Ratio: 0.0010 Service: YES Breakdown: N/A CO2 Reading: 9.34 % CO Reading: 93 ppm

Boiler Make: Worcester Boiler Model: Zwb 32 Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution				
Ventilation Size/H-L				
Water/Fuel - Sound				
Electrically Fused				
Correct Valving Arrangement				
Isolation Available - Electrical/Fuel (Within 1 metre)				
Boiler/Plant room Clean & Clear				
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger				
Ignition				
Gas Valve				
Fan				NA
Safety Device				NA
Control Box				
Burner & Pilot				
Fuel Pressure & Type				
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound		YES		
Interlocks in Place				

Additional Notes

replaced gas valve and spark electrodes

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival:
Gas ID Number 4464997 Time of Departure:
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date:
Report Received By Name: Signature: Date: