

Gas Service/Breakdown Record

Certificate Ref.

27 Touchstone Road

Certificate No 27 Touchstone Road

Installation Details

Installation Address: Steve Tyrell
27 Touchstone Road
Warwick Gates
Warwick
Postcode: CV34 6EE

Client Details

Client Address: Steve Tyrell
27 Touchstone Road
Warwick Gates
Warwick
Postcode: CV34 6EE

Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: N/A CO2 Reading: 10.1 % CO Reading: 110 ppm

Boiler Make: Worcester Boiler Model: Greenstar 8000 Life Boiler Serial No:
Appliance Make: Worcester Appliance Model: GR8701iw 30 S Ng Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title: N/A
N/A
Postcode: N/A

Gas Safe Number: N/A Time of Arrival: N/A
Gas ID Number: N/A Time of Departure: N/A
Telephone Number: N/A

Report Issued By Name: N/A Signature: Date:
Report Received By Name: Signature: Date: