



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.  
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

5 Clement House 2024

Certificate No: 5 Clement House 2024

## Engineers Details

Trading Title  
Coventry Gas Services Ltd

Address  
47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation  
Address

5 Clement House The Blundells, Kenilworth, CV8 2P  
5 Clement House The Blundells, Kenilworth, CV8 2P  
5 Clement House The Blundells, Kenilworth, CV8 2P  
5 Clement House The Blundells, Kenilworth, CV8 2P

Post Code:

## Client Details

Client  
Address

Marston Property Management Ltd  
C/o Leaders 1 Warwick Road Kenilworth  
C/o Leaders 1 Warwick Road Kenilworth  
C/o Leaders 1 Warwick Road Kenilworth

Post Code: CV81HD

Telephone No:

Telephone No:

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type | Make      | Model             | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|----------------|-----------|-------------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen         | Hob            | Stoves    | Unknown           | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 22 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 2 | Airing Cupboard | Combi Boiler   | Worcester | Greenstar 30i Erp | 9.7             | 50               | RS                   | YES                                                              | 0.0005                               | YES                             | 30.17 kw                                     | YES                                            | YES                                         | YES                                                               | N/A                                  | YES                            | YES                            |
| 3 |                 |                |           |                   |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |                 |                |           |                   |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                |           |                   |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sat-11-Oct-2025

Installation Pass:

YES

CO Alarm fitted & working?

NO

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Fri-11-Oct-2024

Report Received By:

Name:

Signed:

Date: Fri-11-Oct-2024

Gas ID Number: 5545563