

Non-Domestic Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.

Certificate Reference

5 Radford Rd 2024

Certificate No: 5 Radford Rd 2024

Engineers Details

Trading Title: Coventry Gas Services Ltd

Address: 47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997 Telephone No: 07961768920

Installation Details

Installation Address: 5 Radford Rd
5 Radford Rd
Leamington Spa

Post Code: CV31 1NG

Telephone No:

Client Details

Client Address: Broadway 69Ltd
10 Shallowford Grove
Milton Keynes

Post Code: MK4 1ND

Telephone No: 07931601793

Appliance Details**Inspection Details**

	Location	Appliance Type	Make	Model	CO2 Reading	CO Reading	FlueType (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar)	Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Hob	Lamona	Na	NA	NA	FL	YES	NA	YES	19	6.45	YES	YES	NA	NA	NO	YES
2	Kitchen	Hob 1	Lamona	Na	NA	NA	FL	YES	NA	YES	18	6.34	YES	YES	NA	NA	NO	YES
3	Airing Cupboard	Central Heating Boiler	Baxi	MEGAFLO 32 HE A	9.5	47	RS	YES	0.0005	YES	NA	30.25	YES	YES	YES	NA	NO	YES
4																		
5																		

Faults/Notes**Remedial Work Taken****Warning Notice Fixed**

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Thu-14-Aug-2025

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Wed-14-Aug-2024

Report Received By:

Name: Andrew King-Page

Signed:

Date: Wed-14-Aug-2024

Gas ID Number:

5545563