



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

24 Bury Road 2024

Certificate No: 24 Bury Road 2024

## Engineers Details

Trading Title Coventry Gas Services Ltd

Address 47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation Address

24 Bury Road Leamington Spa CV31 3HN  
24 Bury Road Leamington Spa CV31 3HN  
24 Bury Road Leamington Spa CV31 3HN  
24 Bury Road Leamington Spa CV31 3HN

Post Code: CV31 3HN

## Client Details

Client Address

Ms Fracasso  
C/o Leaders  
10 Parade  
Leamington Spa

Post Code: CV32 4DW

## Appliance Details

## Inspection Details

|   | Location | Appliance Type | Make           | Model             | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|----------|----------------|----------------|-------------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Utility  | Combi Boiler   | Ideal          | I2 COMBI 30       | 45              | 47               | RS                   | YES                                                              | 0.0005                               | YES                             | 30.17 kw                                     | YES                                            | YES                                         | YES                                                               | N/A                                  | YES                            | YES                            |
| 2 | Kitchen  | Cooker         | Hotpoint       | HD5G00K           | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 20 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 3 | Lounge   | Fire           | Valor Gas fire | HOMEFLAME CLASSIC | NA              | NA               | OF                   | YES                                                              | NA                                   | YES                             | NA mb                                        | NO                                             | YES                                         | YES                                                               | FAIL                                 | NO                             | NA                             |
| 4 |          |                |                |                   |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |          |                |                |                   |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                      |                                                                            |    |
|---|----------------------|----------------------------------------------------------------------------|----|
| 1 | gas fire won't start | capped gas fire off from gas, gas fire no longer connect to the gas supply | NO |
| 2 |                      |                                                                            |    |
| 3 |                      |                                                                            |    |
| 4 |                      |                                                                            |    |
| 5 |                      |                                                                            |    |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Thu-31-Jul-2025

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Thu-01-Aug-2024

Report Received By:

Name:

Signed:

Date: Thu-01-Aug-2024

Gas ID Number: 5545563