



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

5 Henry Street 2024

Certificate No: 5 Henry Street 2024

Engineers Details

Trading Title: Coventry Gas Services Ltd

Address: 47 Alspath Road
Meriden
Post Code: CV7 7LU

Gas Safe No: 927997 Telephone No: 07961768920

Installation Details

Installation Address: 5 Henry Street, Kenilworth, England, CV8 2HL
5 Henry Street, Kenilworth, England, CV8 2HL
5 Henry Street, Kenilworth, England, CV8 2HL
5 Henry Street, Kenilworth, England, CV8 2HL
Post Code: CV82HL

Telephone No:

Client Details

Client Address: Miss R Bruce
C/o Leaders 1 Warwick Road, Kenilworth CV8
C/o Leaders 1 Warwick Road, Kenilworth CV8
C/o Leaders 1 Warwick Road, Kenilworth CV8
Post Code: CV8 1HD

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Combi Boiler	Vaillant	EC PRO 24 VUW 246/3-3	8.8	44	RS	YES	0.0005	YES	23.64 kw	YES	YES	YES	N/A	YES	YES
2																	
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: YES Gas Tightness Satisfactory: YES

Gas Installation Pipework Visual Inspection Satisfactory: YES

Number of Appliances Tested: 1 Equipotential Bonding: YES

NEXT INSPECTION DUE ON OR BEFORE: Sun-17-Aug-2025 Installation Pass: YES

CO Alarm fitted & working? YES Smoke alarm fitted & working? YES

Signatures

Report Issued By:

Name: Andrew King-Page

Report Received By:

Name:

Gas ID Number: 5545563

Signed:

Date: Tue-16-Jul-2024

Signed:

Date: Tue-16-Jul-2024