



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

Flat 7 34 Newbold 2024

Certificate No: Flat 7 34 Newbold 2024

Engineers Details

Trading Title: Coventry Gas Services Ltd

Address: 47 Alspath Road
Meriden
Post Code: CV7 7LU

Gas Safe No: 927997 Telephone No: 07961768920

Installation Details

Installation Address: Flat 7
Flat 7
34 Newbold Terrace East
Leamington Spa
Post Code: CV32 4EY

Telephone No:

Client Details

Client Address: Broadway 69 Ltd
10 Shallowford Grove
Milton Keynes
Post Code: MK4 1ND

Telephone No: 07931601793

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Hob	Lamona	Na	NA	NA	FL	YES	NA	YES	19 mb	YES	YES	NA	N/A	NO	YES
2	Kitchen	Combi Boiler	Worcester	28i Junior	9.0	45	RS	YES	0.0005	YES	27.49 kw	YES	YES	YES	N/A	NO	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: YES Gas Tightness Satisfactory: YES

Gas Installation Pipework Visual Inspection Satisfactory: YES

Number of Appliances Tested: 2 Equipotential Bonding: YES

NEXT INSPECTION DUE ON OR BEFORE: Mon-19-May-2025 Installation Pass: YES

CO Alarm fitted & working? YES Smoke alarm fitted & working? YES

Signatures

Report Issued By:

Name: Andrew King-Page

Report Received By:

Name:

Gas ID Number: 5545563

Signed:

Date: Thu-16-May-2024

Signed:

Date: Thu-16-May-2024