



WARNING NOTICE - DANGER DO NOT USE

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure

Certificate No.

109 Westlea Road War

Registered Business Details

Coventry Gas Services Ltd

47 Alspath Road

Meriden

07961768920

Postcode: CV7 7LU

Installation Details

109 Westlea Road, Royal Leamington Spa, England

109 Westlea Road, Royal Leamington Spa, England

109 Westlea Road, Royal Leamington Spa, England

109 Westlea Road, Royal Leamington Spa, England

Postcode: CV31 3JE

Client Details

Ms L Dix

C/o Leaders 10 Parade, Leamington Spa CV32 4DW

C/o Leaders 10 Parade, Leamington Spa CV32 4DW

Postcode:

1. THE GAS APPLIANCE / GAS INSTALLATION

Make: Bush

Model: AG66TSS

Type: Cooker

Serial No:

Installation Details: (e.g. gas pipework, gas meter)

Fixed in the room / location: (if known) Kitchen

2. IS UNSAFE AND HAS BEEN CATEGORISED IMMEDIATELY DANGEROUS (ID) because:

☐ NA A gas escape has been detected on the appliance / installation or

☐ _____ and

☐ NA with your permission it has been disconnected from the gas supply and a DANGER DO NOT USE label attached or,

☐ NA as you have refused to allow it to be made safe, a DANGER DO NOT USE label has been attached*

Gas Emergency Contact Centre Reference: _____

4. RIDDOR:

☐ The unsafe situation(s) identified is reportable to the Health and Safety Executive (HSE) under RIDDOR

5. REMEDIAL ACTION REQUIRED:

tenant refused isolation

FOR YOUR OWN SAFETY 'IMMEDIATELY DANGEROUS' & 'AT RISK' GAS APPLIANCES / INSTALLATIONS SHOULD NOT BE USED

Gas User/Responsible Person Declaration: I confirm that I have received this Warning Notice concerning the safety of the gas installation. I understand that the use of the appliance/installation in case of an **IMMEDIATELY DANGEROUS** or **AT RISK** installation, could present a danger and could place me in breach of the Gas Safety (Installation and Use) Regulations.

Signed: _____ Print Name: _____

Date: Wed-24-Apr-2024

The gas user was not present at the time of visit, the installation has been made safe and this notice left on the premises.

☐ NA

Gas Operative Declaration: I confirm that the situation(s) recorded above, has been identified and brought to the attention of the Gas User/Responsible Person in accordance with the Gas Safety (Installation and Use) Regulations (GSIUR), Industry Standards and Procedures.

Licence No: 5545563

927997

Signed: _____

Print Name: Andrew King-Page

Issue Date: Wed-24-Apr-2024

Issue Time: 10:33 am