



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

Flat 1 13 St Marys 4

Certificate No: Flat 1 13 St Marys 4

## Engineers Details

Trading Title Coventry Gas Services Ltd

Address 47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation Address Flat 1  
13 St Mary's Rd  
Leamington Spa

Post Code: CV311JN

Telephone No:

## Client Details

Client Address BROADWAY69 LTD  
10 Shallowford Grove  
Milton Keynes

Post Code: MK4 1ND

Telephone No: 07931601793

## Appliance Details

## Inspection Details

|   | Location | Appliance Type | Make     | Model    | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure(mbar) or Heat Input(kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|----------|----------------|----------|----------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|--------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen  | Hob            | Diplomat | Na       | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 18 mb                                      | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 2 | Bathroom | Combi Boiler   | Glowworm | GW 24CXI | 8.8             | 44               | RS                   | YES                                                              | 0.0005                               | YES                             | 23.49 kw                                   | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 3 |          |                |          |          |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |          |                |          |          |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |          |                |          |          |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                                                    |                  |    |
|---|----------------------------------------------------|------------------|----|
| 1 | burner on hob does not light with spark generation | advised landlord | NO |
| 2 | boiler is showing signs of age related decay       | advised landlord | NO |
| 3 |                                                    |                  |    |
| 4 |                                                    |                  |    |
| 5 |                                                    |                  |    |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Fri-21-Mar-2025

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Tue-19-Mar-2024

Report Received By:

Name: Andrew King-Page

Signed:

Date: Tue-19-Mar-2024

Gas ID Number: 5545563