



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

8 Antony Gardner Crescent

Certificate No: 8 Antony Gardner Crescent

## Engineers Details

Trading Title  
Coventry Gas Services Ltd

Address  
47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation Address  
8 Antony Gardner Crescent

Whitnash  
Leamington Spa

Post Code: CV31 2TQ

## Client Details

Client Address  
Brendan Duffy  
C/o Leaders  
10 Parade  
Leamington Spa

Post Code: CV32 4DW

## Appliance Details

## Inspection Details

|   | Location | Appliance Type | Make      | Model      | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|----------|----------------|-----------|------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Lounge   | Fire           | Straxgas  | Unknown    | NA              | NA               | OF                   | YES                                                              | NA                                   | YES                             | NA mb                                        | NO                                             | YES                                         | YES                                                               | FAIL                                 | NO                             | NO                             |
| 2 | Kitchen  | Hob            | Zanussi   | Built in   | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 18 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 3 | Kitchen  | Combi Boiler   | Potterton | SUPRIMA 30 | 7.5             | 37               | RS                   | YES                                                              | 0.0005                               | YES                             | 15.38 kw                                     | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 4 |          |                |           |            |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |          |                |           |            |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                                                                                   |                             |    |
|---|-----------------------------------------------------------------------------------|-----------------------------|----|
| 1 | gas fire has been capped previously to visit, has no gas supply so unable to test | advised tenant and landlord | NO |
| 2 |                                                                                   |                             |    |
| 3 |                                                                                   |                             |    |
| 4 |                                                                                   |                             |    |
| 5 |                                                                                   |                             |    |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sat-26-Oct-2024

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Wed-18-Oct-2023

Report Received By:

Name:

Signed:

Date: Wed-18-Oct-2023

Gas ID Number: 5545563