



WARNING NOTICE - DANGER DO NOT USE

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure

Certificate No.

6 Cherry Orchard War2

Registered Business Details

Coventry Gas Services Ltd

47 Alspath Road

Meriden

07961768920

Postcode: CV7 7LU

Installation Details

6 Cherry Orchard ☐ ☐ Kenilworth ☐ ☐ CV8 2SZ

6 Cherry Orchard ☐ ☐ Kenilworth ☐ ☐ CV8 2SZ

6 Cherry Orchard ☐ ☐ Kenilworth ☐ ☐ CV8 2SZ

6 Cherry Orchard ☐ ☐ Kenilworth ☐ ☐ CV8 2SZ

Postcode: CV8 2SZ

Client Details

Mrs Erskine

C/o Leaders

1 Warwick Road

Kenilworth

Postcode: CV8 1HD

1. THE GAS APPLIANCE / GAS INSTALLATION

Make:

Model:

Type:

Serial No:

Installation Details: (e.g. gas pipework, gas meter)

Fixed in the room / location: (if known)

2. IS UNSAFE AND HAS BEEN CATEGORISED IMMEDIATELY DANGEROUS (ID) because:

☐ NA A gas escape has been detected on the appliance / installation or

☐ _____ and

☐ NA with your permission it has been disconnected from the gas supply and a DANGER DO NOT USE label attached or,

☐ NA as you have refused to allow it to be made safe, a DANGER DO NOT USE label has been attached*

Gas Emergency Contact Centre Reference:

4. RIDDOR:

☐ The unsafe situation(s) identified is reportable to the Health and Safety Executive (HSE) under RIDDOR

5. REMEDIAL ACTION REQUIRED:

advised tenant of the fault and consequences, the tenant declined isolation to the gas meter

3. IS UNSAFE AND HAS BEEN CATEGORISED AT RISK (AR) because:

☐ YES gas pipework exits through top of meter box

☐ NA with your permission it has been TURNED OFF and a DANGER DO NOT USE label attached or,

☐ YES as you have refused to allow it to be made safe, it has a DANGER DO NOT USE label attached

☐ turning off will not reduce the risk, please contact the following to undertake further investigation

Name: Tel No:

*PLEASE NOTE: Registered gas operatives are required by law to report cases where they are refused permission to disconnect an IMMEDIATELY DANGEROUS gas installations to the Gas Emergency Service Call Centre for Natural Gas or for Liquefied Petroleum Gas (LPG), the supplier. All Gas Transporters (GT's) operate a gas emergency service and have powers under the Gas Safety (Rights of Entry) Regulations to visit properties and disconnect unsafe gas appliances / installations.

FOR YOUR OWN SAFETY 'IMMEDIATELY DANGEROUS' & 'AT RISK' GAS APPLIANCES / INSTALLATIONS SHOULD NOT BE USED

Gas User/Responsible Person Declaration: I confirm that I have received this Warning Notice concerning the safety of the gas installation. I understand that the use of the appliance/installation in case of an **IMMEDIATELY DANGEROUS** or **AT RISK** installation, could present a danger and could place me in breach of the Gas Safety (Installation and Use) Regulations.

Signed:  Print Name: Celine Duraffourd

Date: Tue-17-Oct-2023

The gas user was not present at the time of visit, the installation has been made safe and this notice left on the premises.

☐ NA

Gas Operative Declaration: I confirm that the situation(s) recorded above, has been identified and brought to the attention of the Gas User/Responsible Person in accordance with the Gas Safety (Installation and Use) Regulations (GSIUR), Industry Standards and Procedures.

Licence No: 5545563

927997

Signed: 

Print Name: Andrew King-Page

Issue Date: Tue-17-Oct-2023

Issue Time: 10:45 am