



West Lothian Gas



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

72 Keir Close Leamington Spa
Warwickshire CV32 5WE 2

Certificate No: 72 Keir Close Leamington
Spa Warwickshire CV32
5WE 2

Engineers Details

Trading Title Coventry Gas Services Ltd

Address 47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

Installation Details

Installation Address 72 Keir Close
72 Keir Close
Leamington Spa
Warwickshire

Post Code: CV32 5WE

Telephone No: 07465665166

Client Details

Client Address Reeds Rains
24 Warwick Road
Kenilworth

Post Code: CV8 1HE

Telephone No: 01926 857646

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Hob	Beiling	Unknown	NA	NA	FL	YES	NA	YES	19 mb	NA	YES	NA	N/A	NO	YES
2	Lounge	Fire	Magiglo	Duo0010637	NA	NA	OF	YES	NA	YES	NA kw	YES	YES	YES	PASS	NO	NO
3	Airing Cupboard	Central Heating Boiler	Vaillant	Ecotec Plus 831	9.0	90	RS	YES	0.0010	YES	28.94 kw	YES	YES	YES	N/A	NO	YES
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1	gas fire coals not set correctly and broken	advised landlord	NO
2			
3			
4			
5			

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

NO

Number of Appliances Tested:

3

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON OR BEFORE:

Mon-21-Oct-2024

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Wed-11-Oct-2023

Report Received By:

Name:

Signed:

Date: Wed-11-Oct-2023

Gas ID Number: 5545563