



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

57 Monticello Way

Certificate No: 57 Monticello Way

## Engineers Details

Trading Title: Coventry Gas Services Ltd

Address: 47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation Address

57 Monticello Way Coventry CV4 9AL

57 Monticello Way Coventry CV4 9AL

57 Monticello Way Coventry CV4 9AL

57 Monticello Way Coventry CV4 9AL

Post Code: CV4 9AL

## Client Details

Client Address

Dorstairs Property Limited

C/o Leaders

1 Warwick Road

Kenilworth

Post Code: CV8 1HD

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type         | Make    | Model         | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|------------------------|---------|---------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen         | Hob                    | Unknown | Unknown       | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 18 mb                                        | YES                                            | NA                                          | NA                                                                | N/A                                  | NO                             | YES                            |
| 2 | Airing Cupboard | Central Heating Boiler | Ideal   | LOGIC HEAT 15 | 9.5             | 48               | RS                   | YES                                                              | 0.0005                               | YES                             | 13.98 kw                                     | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 3 |                 |                        |         |               |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |                 |                        |         |               |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                        |         |               |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sun-25-Aug-2024

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Fri-25-Aug-2023

Report Received By:

Name:

Signed:

Date: Fri-25-Aug-2023

Gas ID Number: 5545563