



WARNING NOTICE - DANGER DO NOT USE

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure

Certificate No.

62 Turberville Place War

Registered Business Details	Installation Details	Client Details
Coventry Gas Services Ltd 47 Alspath Road Meriden 07961768920 Postcode: CV7 7LU	62 Turberville Place □ □ Warwick □ □ CV34 4JZ 62 Turberville Place □ □ Warwick □ □ CV34 4JZ 62 Turberville Place □ □ Warwick □ □ CV34 4JZ 62 Turberville Place □ □ Warwick □ □ CV34 4JZ Postcode: CV34 4JZ	Miss J Woodward C/o Leaders 10 Parade Leamington Spa Postcode: CV32 4DW

1. THE GAS APPLIANCE / GAS INSTALLATION

Make: Model: Type: Serial No:

Installation Details: (e.g. gas pipework, gas meter) _____

Fixed in the room / location: (if known)

2. IS UNSAFE AND HAS BEEN CATEGORISED IMMEDIATELY DANGEROUS (ID) because:	3. IS UNSAFE AND HAS BEEN CATEGORISED AT RISK (AR) because:
☐ NA A gas escape has been detected on the appliance / installation or ☐ _____ and ☐ NA with your permission it has been disconnected from the gas supply and a DANGER DO NOT USE label attached or, ☐ NA as you have refused to allow it to be made safe, a DANGER DO NOT USE label has been attached* Gas Emergency Contact Centre Reference: _____	☐ YES incorrectly supported flue in loft ☐ YES with your permission it has been TURNED OFF and a DANGER DO NOT USE label attached or, ☐ as you have refused to allow it to be made safe, it has a DANGER DO NOT USE label attached ☐ turning off will not reduce the risk, please contact the following to undertake further investigation Name: your installer Tel No:

4. RIDDOR:

☐ The unsafe situation(s) identified is reportable to the Health and Safety Executive (HSE) under RIDDOR

5. REMEDIAL ACTION REQUIRED:

turned off and isolated boiler as advised by compliance team

FOR YOUR OWN SAFETY 'IMMEDIATELY DANGEROUS' & 'AT RISK' GAS APPLIANCES / INSTALLATIONS SHOULD NOT BE USED

Gas User/Responsible Person Declaration: I confirm that I have received this Warning Notice concerning the safety of the gas installation. I understand that the use of the appliance/installation in case of an IMMEDIATELY DANGEROUS or AT RISK installation, could present a danger and could place me in breach of the Gas Safety (Installation and Use) Regulations.	Gas Operative Declaration: I confirm that the situation(s) recorded above, has been identified and brought to the attention of the Gas User/Responsible Person in accordance with the Gas Safety (Installation and Use) Regulations (GSIUR), Industry Standards and Procedures.
Signed: _____ Print Name: Andrew King-Page	Licence No: 5545563 927997
Date: Tue-08-Aug-2023	Signed:  Print Name: Andrew King-Page
The gas user was not present at the time of visit, the installation has been made safe and this notice left on the premises. ☐ NA	Issue Date: Tue-08-Aug-2023 Issue Time: 10:15 am