



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

6 Hornbeam Drive 1

Certificate No: 6 Hornbeam Drive 1

## Engineers Details

Trading Title  
Coventry Gas Ltd

Address  
47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

## Installation Details

Installation Address  
6 Hornbeam Drive  
6 Hornbeam Drive  
Coventry

Post Code: CV4 9UJ

## Client Details

Client Address  
H2L Lettings  
38 Main Road  
Meriden

Post Code: CV7 7NF

## Appliance Details

## Inspection Details

|   | Location | Appliance Type         | Make      | Model     | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure(mbar) or Heat Input(kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|----------|------------------------|-----------|-----------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|--------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen  | Central Heating Boiler | Potterton | PRIMA 30F | NA              | NA               | RS                   | YES                                                              | NA                                   | YES                             | 11.34 kw                                   | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 2 |          |                        |           |           |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 3 |          |                        |           |           |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |          |                        |           |           |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |          |                        |           |           |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                                      |                                         |     |
|---|--------------------------------------|-----------------------------------------|-----|
| 1 | smoke alarm on landing inoperable    | advised landlord                        | NO  |
| 2 | boiler casing failing off due to age | advised landlord to get boiler replaced | YES |
| 3 |                                      |                                         |     |
| 4 |                                      |                                         |     |
| 5 |                                      |                                         |     |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

1

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Wed-26-Jun-2024

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

NO

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Mon-26-Jun-2023

Report Received By:

Name: Andrew King-Page

Signed:

Date: Mon-26-Jun-2023

Gas ID Number: 4464997