



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

80 Henry Street Kenilworth
Warwickshire CV8 2HJ

Certificate No: 80 Henry Street Kenilworth
Warwickshire CV8 2HJ

Engineers Details

Trading Title Coventry Gas Ltd

Address 47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

Installation Details

Installation Address

works order LSP22000147

80 Henry Street Kenilworth Warwickshire CV8 2HJ

80 Henry Street Kenilworth Warwickshire CV8 2HJ

80 Henry Street Kenilworth Warwickshire CV8 2HJ

Post Code: CV8 2HJ

Telephone No:

Client Details

Client Address

Miss Elizabeth Stokes c/o Reeds Rains Ltd

34/35 Denby Buildings

Regent Grove

Leamington Spa

Post Code: CV32 4NY

Telephone No: 01926 311431

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Airing Cupboard	Combi Boiler	Worcester	Greenstar 28cdi Comp	9.2	49	RS	YES	0.0005	YES	27.45 kw	YES	YES	YES	N/A	NO	YES
2	Kitchen	Cooker	Currys	Cfscwh17	NA	NA	FL	YES	NA	YES	22 mb	YES	YES	NA	N/A	NO	YES
3	Lounge	Fire	Nuflame	Ga150	NA	NA	OF	YES	NA	YES	NA kw	NO	YES	YES	N/A	NO	NO
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1	gas fire capped previously	none	NO
2	no carbon monoxide alarm in kitchen	advised landlord	NO
3			
4			
5			

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Tue-21-Nov-2023

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Mon-21-Nov-2022

Report Received By:

Name:

Signed:

Date: Mon-21-Nov-2022

Gas ID Number: 4464997