



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

72 Keir Close Leamington Spa  
Warwickshire CV32 5WE 1

Certificate No: 72 Keir Close Leamington  
Spa Warwickshire CV32  
5WE 1

## Engineers Details

Trading Title Coventry Gas Ltd

Address 47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

## Installation Details

Installation Address 72 Keir Close  
72 Keir Close  
Leamington Spa  
Warwickshire

Post Code: CV32 5WE

Telephone No: 07465665166

## Client Details

Client Address Reeds Rains  
35 Regent Grove  
Leamington Spa

Post Code: CV32 4NY

Telephone No: 01926311431

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type         | Make     | Model           | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure(mbar) or Heat Input(kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|------------------------|----------|-----------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|--------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen         | Hob                    | Beiling  | Unknown         | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 20 mb                                      | NA                                             | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 2 | Lounge          | Fire                   | Magiglo  | Duo0010637      | NA              | NA               | OF                   | YES                                                              | NA                                   | YES                             | NA kw                                      | YES                                            | YES                                         | YES                                                               | PASS                                 | NO                             | NO                             |
| 3 | Airing Cupboard | Central Heating Boiler | Vaillant | Ecotec Plus 831 | 9.4             | 47               | RS                   | YES                                                              | 0.0005                               | YES                             | 29.30 kw                                   | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 4 |                 |                        |          |                 |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                        |          |                 |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                                                       |                  |    |
|---|-------------------------------------------------------|------------------|----|
| 1 | burner on gas hob doesn't ignite with spark generator | advised landlord | NO |
| 2 | gas fire coals not set correctly and broken           | advised landlord | NO |
| 3 |                                                       |                  |    |
| 4 |                                                       |                  |    |
| 5 |                                                       |                  |    |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

NO

Number of Appliances Tested:

3

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON OR BEFORE:

Sat-21-Oct-2023

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Tue-01-Nov-2022

Report Received By:

Name:

Signed:

Date: Tue-01-Nov-2022

Gas ID Number: 4464997