



# WARNING NOTICE - DANGER DO NOT USE

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure

Certificate No.

115 Brockworth Road Druids Heath  
Birmingham B14 5YJ 2

| Registered Business Details                                                            | Installation Details                                                                                                              | Client Details                                                                                                 |
|----------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|
| Coventry Gas Ltd<br>47 Alspath Road<br>Meriden<br><br>07961768920<br>Postcode: CV7 7LU | 115 Brockworth Road Druids Heath Birmingham B14 5Y<br>115 Brockworth Road Druids Heath Birmingham B14 5Y<br><br>Postcode: B14 5YJ | Black And Golds Estate Agents<br>117 Stratford Rd<br>Shirley<br>Solihull<br>0121 249 6207<br>Postcode: B90 3ND |

## 1. THE GAS APPLIANCE / GAS INSTALLATION

Make: Worcester Model: 28i JUNIOR RSF Type: Combi Boiler Serial No:   
Installation Details: (e.g. gas pipework, gas meter)   
Fixed in the room / location: (if known) Airing Cupboard

## 2. IS UNSAFE AND HAS BEEN CATEGORISED IMMEDIATELY DANGEROUS (ID) because:

- ☐ NA A gas escape has been detected on the appliance / installation or   
 ☐ \_\_\_\_\_ and   
 ☐ NA with your permission it has been disconnected from the gas supply and a DANGER DO NOT USE label attached or,   
 ☐ NA as you have refused to allow it to be made safe, a DANGER DO NOT USE label has been attached\*   
 Gas Emergency Contact Centre Reference: \_\_\_\_\_

## 4. RIDDOR:

☐ The unsafe situation(s) identified is reportable to the Health and Safety Executive (HSE) under RIDDOR

## 5. REMEDIAL ACTION REQUIRED:

advised landlord

## 3. IS UNSAFE AND HAS BEEN CATEGORISED AT RISK (AR) because:

- ☐ YES flue not screwed and unsupported   
 ☐ YES with your permission it has been TURNED OFF and a DANGER DO NOT USE label attached or,   
 ☐ as you have refused to allow it to be made safe, it has a DANGER DO NOT USE label attached   
 ☐ turning off will not reduce the risk, please contact the following to undertake further investigation   
 Name: \_\_\_\_\_ Tel No: \_\_\_\_\_

\*PLEASE NOTE: Registered gas operatives are required by law to report cases where they are refused permission to disconnect an IMMEDIATELY DANGEROUS gas installations to the Gas Emergency Service Call Centre for Natural Gas or for Liquefied Petroleum Gas (LPG), the supplier. All Gas Transporters (GT's) operate a gas emergency service and have powers under the Gas Safety (Rights of Entry) Regulations to visit properties and disconnect unsafe gas appliances / installations.

## FOR YOUR OWN SAFETY 'IMMEDIATELY DANGEROUS' & 'AT RISK' GAS APPLIANCES / INSTALLATIONS SHOULD NOT BE USED

**Gas User/Responsible Person Declaration:** I confirm that I have received this Warning Notice concerning the safety of the gas installation. I understand that the use of the appliance/installation in case of an **IMMEDIATELY DANGEROUS** or **AT RISK** installation, could present a danger and could place me in breach of the Gas Safety (Installation and Use) Regulations.

Signed: \_\_\_\_\_ Print Name: \_\_\_\_\_

Date: Wed-26-Oct-2022

The gas user was not present at the time of visit, the installation has been made safe and this notice left on the premises.

NA

**Gas Operative Declaration:** I confirm that the situation(s) recorded above, has been identified and brought to the attention of the Gas User/Responsible Person in accordance with the Gas Safety (Installation and Use) Regulations (GSIUR), Industry Standards and Procedures.

Licence No: 4464997 526645

Signed: \_\_\_\_\_ Print Name: Andrew King-Page

Issue Date: Wed-26-Oct-2022 Issue Time: 01:32 pm