



WARNING NOTICE - DANGER DO NOT USE

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure

Certificate No.

72 Keir Close Leamington Spa
Warwickshire CV32 5WF War1

Registered Business Details	Installation Details	Client Details
Coventry Gas Ltd 47 Alspath Road Meriden 07961768920 Postcode: CV7 7LU	72 Keir Close 72 Keir Close Leamington Spa Warwickshire 07465665166 Postcode: CV32 5WE	Reeds Rains 35 Regent Grove Leamington Spa 01926311431 Postcode: CV32 4NY

1. THE GAS APPLIANCE / GAS INSTALLATION

Make: Model: Type: Serial No:

Installation Details: (e.g. gas pipework, gas meter) _____

Fixed in the room / location: (if known)

2. IS UNSAFE AND HAS BEEN CATEGORISED IMMEDIATELY DANGEROUS (ID) because:	3. IS UNSAFE AND HAS BEEN CATEGORISED AT RISK (AR) because:
☐ NA A gas escape has been detected on the appliance / installation or ☐ _____ and ☐ NA with your permission it has been disconnected from the gas supply and a DANGER DO NOT USE label attached or, ☐ NA as you have refused to allow it to be made safe, a DANGER DO NOT USE label has been attached* Gas Emergency Contact Centre Reference: _____	☐ YES gas pipework exits meter in incorrect position, equipotential bonding not before the first tee, meter not sealed at rear exit ☐ NA with your permission it has been TURNED OFF and a DANGER DO NOT USE label attached or, ☐ as you have refused to allow it to be made safe, it has a DANGER DO NOT USE label attached ☐ YES turning off will not reduce the risk, please contact the following to undertake further investigation Name: _____ Tel No: _____

4. RIDDOR:

☐ The unsafe situation(s) identified is reportable to the Health and Safety Executive (HSE) under RIDDOR

*PLEASE NOTE: Registered gas operatives are required by law to report cases where they are refused permission to disconnect an IMMEDIATELY DANGEROUS gas installations to the Gas Emergency Service Call Centre for Natural Gas or for Liquefied Petroleum Gas (LPG), the supplier. All Gas Transporters (GT's) operate a gas emergency service and have powers under the Gas Safety (Rights of Entry) Regulations to visit properties and disconnect unsafe gas appliances / installations.

5. REMEDIAL ACTION REQUIRED:

advised landlord and tenant

FOR YOUR OWN SAFETY 'IMMEDIATELY DANGEROUS' & 'AT RISK' GAS APPLIANCES / INSTALLATIONS SHOULD NOT BE USED

Gas User/Responsible Person Declaration: I confirm that I have received this Warning Notice concerning the safety of the gas installation. I understand that the use of the appliance/installation in case of an **IMMEDIATELY DANGEROUS** or **AT RISK** installation, could present a danger and could place me in breach of the Gas Safety (Installation and Use) Regulations.

Signed: _____ Print Name: _____

Date: Fri-21-Oct-2022

The gas user was not present at the time of visit, the installation has been made safe and this notice left on the premises. ☐ NA

Gas Operative Declaration: I confirm that the situation(s) recorded above, has been identified and brought to the attention of the Gas User/Responsible Person in accordance with the Gas Safety (Installation and Use) Regulations (GSIUR), Industry Standards and Procedures.

Licence No: 4464997 526645

Signed:  Print Name: Andrew King-Page

Issue Date: Fri-21-Oct-2022 Issue Time: 09:27 am