



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

8 regent Street B30 2LG 2

Certificate No: 8 regent Street B30 2LG 2

## Engineers Details

Trading Title  
Coventry Gas Ltd

Address  
47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

## Installation Details

Installation  
Address

8 regent Street B30 2LG  
8 regent Street B30 2LG  
8 regent Street B30 2LG  
8 regent Street B30 2LG

Post Code:

## Client Details

Client  
Address

Mike Grendon  
8 regent street  
Birmingham

Post Code: B30 2LG

## Appliance Details

## Inspection Details

|   | Location | Appliance Type | Make    | Model       | CO2 Reading (%) | CO Reading (ppm) | Flue Type<br>(OF/RS/FL) | Appliance<br>Inspected<br>(YES/NO/NA/IO)<br>(IO = Visual Inspection Only) | Combustion<br>Analysis Reading<br>(CO/CO2) | Landlords<br>Appliance<br>(YES/NO/NA) | Operating<br>Pressure(mbar)<br>or<br>Heat Input(kW) | Safety Device(s)<br>Correct<br>Operation<br>(YES/NO/NA) | Ventilation<br>Provision<br>Satisfactory<br>(YES/NO) | Visual Condition<br>Of Flue and<br>Termination<br>Satisfactory<br>(YES/NO/NA) | Flue Performance<br>Test<br>(PASS/FAIL/NA) | Appliance<br>Serviced<br>(YES/NO/NA) | Appliance<br>Safe To Use<br>(YES/NO) |
|---|----------|----------------|---------|-------------|-----------------|------------------|-------------------------|---------------------------------------------------------------------------|--------------------------------------------|---------------------------------------|-----------------------------------------------------|---------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------------------------|--------------------------------------------|--------------------------------------|--------------------------------------|
| 1 | Kitchen  | Combi Boiler   | Ariston | Clas One 24 | 9.05            | 44               | RS                      | YES                                                                       | 0.0005                                     | YES                                   | 24.19 kw                                            | YES                                                     | YES                                                  | YES                                                                           | N/A                                        | YES                                  | YES                                  |
| 2 | Kitchen  | Hob            | Unknown | Unknown     | NA              | NA               | FL                      | YES                                                                       | NA                                         | YES                                   | 21 mb                                               | YES                                                     | YES                                                  | NA                                                                            | N/A                                        | NO                                   | YES                                  |
| 3 |          |                |         |             |                 |                  |                         |                                                                           |                                            |                                       |                                                     |                                                         |                                                      |                                                                               |                                            |                                      |                                      |
| 4 |          |                |         |             |                 |                  |                         |                                                                           |                                            |                                       |                                                     |                                                         |                                                      |                                                                               |                                            |                                      |                                      |
| 5 |          |                |         |             |                 |                  |                         |                                                                           |                                            |                                       |                                                     |                                                         |                                                      |                                                                               |                                            |                                      |                                      |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve  
Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON  
OR BEFORE:

Fri-23-Sep-2022

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Mon-19-Sept-2022

Report Received By:

Name:

Signed:

Date: Mon-19-Sept-2022

Gas ID Number: 4464997