



West Lothian Gas



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

188 Emscote Road-Stuart
Cole-07Jun2022

Certificate No: 188 Emscote Road Gs

Engineers Details

Trading Title: Coventry Gas Ltd
Address: 47 Alspath Road
Meriden
Meriden
Post Code: CV7 7LU
Gas Safe No: 526645
Telephone No: 07502848685

Installation Details

Installation Address: Stuart Cole
188 Emscote Road
Warwick
Post Code: CV34 5QN
Telephone No: 07971666080

Client Details

Client Address: Stuart Cole
188 Emscote Road
Warwick
Post Code: CV34 5QN
Telephone No: 07971666080

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Combi Boiler	Worcester	Greenstar 25i	9.6	75	RS	YES	0.0008	YES	24.67 kw	YES	YES	YES	PASS	YES	YES
2	Lounge	Fire	Morso	140	NA	NA	OF	NO	NA	YES	5.69 kw	YES	YES	YES	PASS	NO	YES
3	Kitchen	Oven	Beiling	1000f	NA	NA	N/A	YES	NA	YES	NA mb	YES	NA	NA	N/A	NO	YES
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

NA

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Wed-07-Jun-2023

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

Signatures

Report Issued By:

Name: Steve Owen

Signed: _____

Gas ID Number: Na

Date: Tue-07-Jun-2022

Report Received By:

Name: _____

Signed: _____

Date: Tue-07-Jun-2022