



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

Mews Cottage-Oliver
Gazlev-11May2022

Certificate No: Mews Cottage

Engineers Details

Trading Title Coventry Gas Ltd

Address 47 Alspath Road
Meriden
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07502848685

Installation Details

Installation Address Oliver Gazley
Mews Cottage
8A Windsor Street
Leamington Spa

Post Code: CV32 5EB

Telephone No: 33768100647

Client Details

Client Address Oliver Gazley
Mews Cottage
8A Windsor Street
Leamington Spa

Post Code: CV32 5EB

Telephone No: 33768100647

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Oven	Stoves	Panache	NA	NA	FL	YES	NA	YES	8.24 kw	YES	YES	YES	PASS	NO	YES
2	Bathroom	Combi Boiler	Worcester	24CDi-RSF/NG	NA	NA	RS	YES	NA	YES	28.51 kw	YES	YES	YES	PASS	YES	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Thu-11-May-2023

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Steve Owen

Signed: _____

Date: Wed-11-May-2022

Report Received By:

Name: _____

Signed: _____

Date: Wed-11-May-2022

Gas ID Number: Na