



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

29 Riplingham Court

Certificate No: 29 Riplingham Court

Engineers Details

Trading Title: Coventry Gas Ltd

Address: 47 Alspath Road
Meriden
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07502848685

Installation Details

Installation Address

29 Riplingham Court
Arlington Avenue
Leamington Spa

Post Code:

Telephone No:

Client Details

Client Address

Scott Dunlop
15 Wheathill Close
Leamington Spa

Post Code: CV32 6PL

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Airing Cupboard	Combi Boiler	Worcester	Greenstar 25 Si	8.9	41	RS	YES	0.0005	YES	24.57 kw	YES	YES	YES	PASS	YES	YES
2	Kitchen	Oven	Newhome	Unknown	NA	NA	N/A	YES	NA	YES	19 mb	YES	NA	NA	N/A	NO	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Wed-19-Apr-2023

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Steve Owen

Signed: _____

Gas ID Number: Na

Date: Tue-19-Apr-2022

Report Received By:

Name: _____

Signed: 

Date: Tue-19-Apr-2022