



WARNING NOTICE - DANGER DO NOT USE

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure

Certificate No.

Rosebank Fentham Road Hampton in Arden W

Registered Business Details	Installation Details	Client Details
Coventry Gas Ltd 47 Alspath Road Meriden 07961768920 Postcode: CV7 7LU	Rosebank Fentham Road Hampton in Arden Postcode: B92 0BB	H2L Lettings 38 Main Road Meriden Postcode: CV7 7NF

1. THE GAS APPLIANCE / GAS INSTALLATION

Make: Model: Type: Serial No:

Installation Details: (e.g. gas pipework, gas meter) _____

Fixed in the room / location: (if known)

2. IS UNSAFE AND HAS BEEN CATEGORISED IMMEDIATELY DANGEROUS (ID) because:

- ☐ NA A gas escape has been detected on the appliance / installation or _____ and _____
- ☐ NA with your permission it has been disconnected from the gas supply and a DANGER DO NOT USE label attached or, _____
- ☐ NA as you have refused to allow it to be made safe, a DANGER DO NOT USE label has been attached*
- Gas Emergency Contact Centre Reference: _____

4. RIDDOR:

☐ The unsafe situation(s) identified is reportable to the Health and Safety Executive (HSE) under RIDDOR

5. REMEDIAL ACTION REQUIRED:

turned off as unsafe

3. IS UNSAFE AND HAS BEEN CATEGORISED AT RISK (AR) because:

- ☐ YES unable to test due to poor condition of boiler
- ☐ YES with your permission it has been TURNED OFF and a DANGER DO NOT USE label attached or, _____
- ☐ as you have refused to allow it to be made safe, it has a DANGER DO NOT USE label attached
- ☐ turning off will not reduce the risk, please contact the following to undertake further investigation
- Name: Tel No:

*PLEASE NOTE: Registered gas operatives are required by law to report cases where they are refused permission to disconnect an IMMEDIATELY DANGEROUS gas installations to the Gas Emergency Service Call Centre for Natural Gas or for Liquefied Petroleum Gas (LPG), the supplier. All Gas Transporters (GT's) operate a gas emergency service and have powers under the Gas Safety (Rights of Entry) Regulations to visit properties and disconnect unsafe gas appliances / installations.

FOR YOUR OWN SAFETY 'IMMEDIATELY DANGEROUS' & 'AT RISK' GAS APPLIANCES / INSTALLATIONS SHOULD NOT BE USED

Gas User/Responsible Person Declaration : I confirm that I have received this Warning Notice concerning the safety of the gas installation. I understand that the use of the appliance/installation in case of an **IMMEDIATELY DANGEROUS** or **AT RISK** installation, could present a danger and could place me in breach of the Gas Safety (Installation and Use) Regulations.

Signed: _____ Print Name: _____

Date:

The gas user was not present at the time of visit, the installation has been made safe and this notice left on the premises.

☐ NA

Gas Operative Declaration: I confirm that the situation(s) recorded above, has been identified and brought to the attention of the Gas User/Responsible Person in accordance with the Gas Safety (Installation and Use) Regulations (GSIUR), Industry Standards and Procedures.

Licence No:

Signed: Print Name:

Issue Date: Issue Time: