



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

308 Westwood Heath Road
Coventry CV4 8GP2

Certificate No: 308 Westwood Heath
Road Coventry CV4 8GP2

Engineers Details

Trading Title Coventry Gas Ltd

Address 47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

Installation Details

Installation Address 308 Westwood Heath Road Coventry CV4 8GP
308 Westwood Heath Road Coventry CV4 8GP

Post Code: CV4 8GP

Telephone No:

Client Details

Client Address H2L Lettings
38 Main Road
Meriden

Post Code: CV7 7NF

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Hob	Bosch	Na	NA	NA	FL	YES	NA	YES	20 mb	YES	YES	NA	N/A	NO	YES
2	Garage	Combi Boiler	Baxi	Platinum 40 Combi	9.38	42	RS	YES	0.0005	YES	37.93 kw	YES	YES	YES	N/A	YES	YES
3	Lounge	Fire	Flavel	Fsrpoomn	NA	NA	OF	YES	NA	YES	NA kw	NO	YES	YES	FAIL	NO	NO
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1	gas fire has missing coal	advised landlord, turned off at risk	YES
2	gas hob centre burner does not ignite	advised landlord	NO
3			
4			
5			

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Fri-17-Mar-2023

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Thu-21-Oct-2021

Report Received By:

Name:

Signed:

Date: Thu-21-Oct-2021

Gas ID Number: 4464997