



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

14 Chivington Close Solihull West Midlands B90 4YS

Certificate No: 14 Chivington Close Solihull West Midlands B90 4YS

## Engineers Details

Trading Title Coventry Gas Ltd

Address 47 Alspath Road Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

## Installation Details

Installation Address

14 Chivington Close Solihull West Midlands B90 4YS  
14 Chivington Close Solihull West Midlands B90 4YS  
14 Chivington Close Solihull West Midlands B90 4YS  
14 Chivington Close Solihull West Midlands B90 4YS

Post Code:

Telephone No:

## Client Details

Client Address

Black And Golds Estate Agents  
117 Stratford Rd  
Shirley  
Solihull

Post Code: B90 3ND

Telephone No: 0121 249 6207

## Appliance Details

## Inspection Details

|   | Location | Appliance Type | Make           | Model            | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|----------|----------------|----------------|------------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Garage   | Combi Boiler   | Ferrolti       | Domicompact F24B | 7.94            | 40               | RS                   | YES                                                              | 0.0006                               | YES                             | 23.62 kw                                     | YES                                            | YES                                         | NO                                                                | N/A                                  | YES                            | YES                            |
| 2 | Lounge   | Fire           | Valor Gas fire | 337              | NA              | NA               | OF                   | YES                                                              | NA                                   | YES                             | 17 mb                                        | YES                                            | YES                                         | YES                                                               | PASS                                 | NO                             | YES                            |
| 3 | Kitchen  | Hob            | Unknown        | Unknown          | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 17 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 4 |          |                |                |                  |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |          |                |                |                  |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                                          |                  |     |
|---|------------------------------------------|------------------|-----|
| 1 | one burner on hob has a clogged injector | advised landlord | NO  |
| 2 | Boiler pressure too high                 | advised landlord | NO  |
| 3 | Boiler flue blocked by vegetation        | advised landlord | YES |
| 4 | main heat exchanger on boiler leaking    |                  | NO  |
| 5 |                                          |                  |     |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Tue-18-Oct-2022

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Mon-18-Oct-2021

Report Received By:

Name:

Signed:

Date: Mon-18-Oct-2021

Gas ID Number: 4464997