



West Lothian Gas



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

2921 6 Carpenter Road Coventry
West Midlands CV2 3PT

Certificate No: 2921 6 Carpenter Road
Coventry West Midlands
CV2 3PT

Engineers Details

Trading Title: Coventry Gas Ltd
Address: 47 Alspath Road
Meriden
Post Code: CV7 7LU

Gas Safe No: 526645 Telephone No: 07961768920

Installation Details

Installation Address: 2921 6 Carpenter Road Coventry West Midlands CV2
2921 6 Carpenter Road Coventry West Midlands CV2
2921 6 Carpenter Road Coventry West Midlands CV2
2921 6 Carpenter Road Coventry West Midlands CV2
Post Code: CV2 3PT

Telephone No:

Client Details

Client Address: Plusheat
PlusHeat
London
Post Code: WC1N 3AX

Telephone No: 020 4513 6769

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Airing Cupboard	Combi Boiler	Vokera	Easi Heat Plus 25C	9.45	47	RS	YES	0.0005	YES	24.23 kw	YES	YES	YES	N/A	YES	YES
2	Kitchen	Hob	Smeg	Unknown	NA	NA	FL	YES	NA	YES	19 mb	YES	YES	NA	N/A	NO	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1	spark ignition does not work on hob		NO
2			
3			
4			
5			

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Wed-15-Jun-2022

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Gas ID Number: 4464997

Date: Tue-15-Jun-2021

Report Received By:

Name:

Signed:

Date: Tue-15-Jun-2021