



Non-Domestic Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.

Certificate Reference

188 Emscote Road 2

Certificate No: 188 Emscote Road

Engineers Details

Trading Title
Coventry Gas Ltd

Address
47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

Installation Details

Installation Address
Stuart Cole
188 Emscote Road
Warwick

Post Code: CV34 5QN

Telephone No: 07971666080

Client Details

Client Address
Stuart Cole
188 Emscote Road
Warwick

Post Code: CV34 5QN

Telephone No: 07971666080

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading	CO Reading	FlueType (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar)	Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Central Heating Boiler	Worcester	Greenstar 25i	8.95	45	RS	YES	0.0005	YES		25.12	YES	NA	YES	NA	YES	YES
2	Kitchen	Oven	Beiling	100DF	NA	NA		YES	NA	YES	19	NA	YES	YES	NA	NA	NO	YES
3	Lounge	Fire	Morso	1480	NA	NA	OF	YES	NA	YES		6.30	YES	YES	YES	PASS	NO	YES
4																		
5																		

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Fri-07-May-2021

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Gas ID Number:

4464997

Date: Tue-08-Jun-2021

Report Received By:

Name: Andrew King-Page

Signed:

Date: Tue-08-Jun-2021