



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

18 Cypress Way Nuneaton CV10 0LG

Certificate No: 18 Cypress Way Nuneaton CV10 0LG

Engineers Details

Trading Title: Coventry Gas Services
Address: 47 Alspath Road, Meriden
Post Code: CV7 7LU
Gas Safe No: 526645
Telephone No: 07961768920

Installation Details

Installation Address: 18 Cypress Way Nuneaton CV10 0LG
18 Cypress Way Nuneaton CV10 0LG
18 Cypress Way Nuneaton CV10 0LG
Post Code: CV100LG
Telephone No:

Client Details

Client Address: H2L Lettings, 38 Main Road, Meriden
Post Code: CV7 7NF
Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Hob	Bosch	Na	NA	NA	FL	YES	NA	YES	18 mb	YES	YES	NA	N/A	NO	YES
2	Garage	Combi Boiler	Vaillant	EC PRO 24 VUW 246/3-3	8.90	45	RS	YES	0.0011	YES	23.98 kw	YES	YES	YES	N/A	NO	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sat-22-May-2021

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Gas ID Number: 4464997

Date: Fri-22-May-2020

Report Received By:

Name:

Signed:

Date: Fri-22-May-2020