



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

6 Cherrywood Court

Certificate No: 6 Cherrywood Court

## Engineers Details

Trading Title: Coventry Gas Services

Address: 47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

## Installation Details

Installation Address: 6 Cherrywood court  
6 Cherrywood court  
Solihull

Post Code: B92 8QS

Telephone No:

## Client Details

Client Address: Michelle Keefe  
73 Knightsbridge Road  
Solihull

Post Code: B92 8TD

Telephone No: 07814113659

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type | Make      | Model                    | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure(mbar) or Heat Input(kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|----------------|-----------|--------------------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|--------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Airing Cupboard | Combi Boiler   | Worcester | Greenstar 28 i junior HE | 9.83            | 90               | RS                   | YES                                                              | 0.0008                               | YES                             | 27.40 kw                                   | YES                                            | YES                                         | YES                                                               | N/A                                  | YES                            | YES                            |
| 2 |                 |                |           |                          |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 3 |                 |                |           |                          |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |                 |                |           |                          |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                |           |                          |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

1

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Tue-30-Mar-2021

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Mon-30-Mar-2020

Report Received By:

Name: Andrew King-Page

Signed:

Date: Mon-30-Mar-2020

Gas ID Number: 4464997