



West Lothian Gas



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

75 Birchfield Road Coventry CV6 2BB

Certificate No: 75 Birchfield Road  
Coventry CV6 2BB

## Engineers Details

Trading Title: Coventry Gas Services

Address: 47 Alspath Road  
Meriden  
Post Code: CV7 7LU

Gas Safe No: 526645 Telephone No: 07961768920

## Installation Details

Installation Address: 75 Birchfield Road, Coventry, CV6 2BB  
75 Birchfield Road, Coventry, CV6 2BB  
Coventry  
Post Code: CV6 2BB

Telephone No:

## Client Details

Client Address: H2L Lettings  
38 Main Road  
Meriden  
Post Code: CV7 7NF

Telephone No:

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type | Make     | Model         | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure(mbar) or Heat Input(kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|----------------|----------|---------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|--------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen         | Hob            | Philips  | Unknown       | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 17 mb                                      | YES                                            | NA                                          | YES                                                               | N/A                                  | NO                             | YES                            |
| 2 | Airing Cupboard | Combi Boiler   | Vaillant | Ecotec Pro 24 | 9.23            | 89               | RS                   | YES                                                              | 0.0008                               | YES                             | 23.67 kw                                   | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 3 |                 |                |          |               |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |                 |                |          |               |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                |          |               |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sun-18-Oct-2020

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Gas ID Number: 4464997

Date: Fri-18-Oct-2019

Report Received By:

Name: Andrew King-Page

Signed:

Date: Fri-18-Oct-2019