



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

334 Grange Road

Certificate No: 334 Grange Road

Engineers Details

Trading Title: Coventry Gas Services

Address: 47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

Installation Details

Installation Address: Benjamin Enwemasor

334 Grange Road
Coventry

Post Code: CV66DE

Telephone No: 07863663344

Client Details

Client Address: Benjamin Enwemasor

334 Grange Road
Coventry

Post Code: CV66DE

Telephone No: 07863663344

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Lounge	Fire	Straxgas	Theme Plus	NA	NA	FL	YES	NA	YES	18 mb	YES	YES	YES	PASS	NO	YES
2	Kitchen	Cooker	Essentials	Cfsgwh14	NA	NA		YES	NA	YES	18 mb	YES	YES	NA	N/A	NO	YES
3	Landing	Combi Boiler	Worcester	28i Junior	9.34	92	RS	YES	0.0010	YES	27.45 kw	YES	YES	YES	N/A	NO	YES
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1	pressure relief valve not terminating towards the wall	advised landlord	NO
2	condense pipe lagging insufficient	advised landlord	NO
3	pressure gauge on boiler inoperable	advised landlord	NO
4	ep bonding not before the first tee	advised landlord	NO
5			

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

NA

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sun-06-Sep-2020

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Fri-06-Sep-2019

Report Received By:

Name: Andrew King-Page

Signed:

Date: Fri-06-Sep-2019

Gas ID Number: 4464997