



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

154 Valley Road 2

Certificate No: 154 Valley Road 2

Engineers Details

Trading Title

Address

Post Code:

Gas Safe No:

Telephone No:

Installation Details

Installation Address

154 Valley Road
154 Valley Road
Leamington Spa

Post Code: CV32 7SD

Telephone No:

Client Details

Client Address

Mr Ian Wood
16 Redcar Close
Leamington Spa

Post Code: CV327SU

Telephone No:

07756721589

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Airing Cupboard	Combi Boiler	Vaillant	TURBOMAX VUW 282 E	3.5	28	RS	YES	0.0008	YES	23.58 kw	YES	YES	YES	N/A	YES	YES
2																	
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

NO

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

NO

Number of Appliances Tested:

1

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON OR BEFORE:

Sat-02-Mar-2024

Installation Pass:

NO

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name:

Signed:

Date:

Report Received By:

Name:

Signed:

Date:

Gas ID Number: