



West Lothian Gas



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

17 Jasmine Grove 2024

Certificate No: 17 Jasmine Grove 2024

## Engineers Details

Trading Title

Address

Post Code:

Gas Safe No:

Telephone No:

## Installation Details

Installation Address

17 Jasmine Grove, Coventry, England, CV3 1EA

17 Jasmine Grove, Coventry, England, CV3 1EA

17 Jasmine Grove, Coventry, England, CV3 1EA

17 Jasmine Grove, Coventry, England, CV3 1EA

Post Code:

## Client Details

Client Address

Mr A Maruszewski

C/o Leaders 1 Warwick Road, Kenilworth CV8

C/o Leaders 1 Warwick Road, Kenilworth CV8

C/o Leaders 1 Warwick Road, Kenilworth CV8

Post Code: CV8 1HD

## Appliance Details

## Inspection Details

|   | Location | Appliance Type | Make  | Model                | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|----------|----------------|-------|----------------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen  | Hob            | Beko  | Unknown              | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 22 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 2 | Kitchen  | Combi Boiler   | Biasi | GARDA HE M96.24 SM/B | 9.4             | 94               | RS                   | YES                                                              | 0.0010                               | YES                             | 23.38 kw                                     | YES                                            | YES                                         | NO                                                                | N/A                                  | NO                             | YES                            |
| 3 |          |                |       |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |          |                |       |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |          |                |       |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                                               |                  |    |
|---|-----------------------------------------------|------------------|----|
| 1 | lead pipework on meter restricting gas flow   | advised landlord | NO |
| 2 | ep bonding not before the first tee           | advised landlord | NO |
| 3 | boiler flue crumbling and restricting airflow | advised landlord | NO |
| 4 |                                               |                  |    |
| 5 |                                               |                  |    |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

NO

Number of Appliances Tested:

2

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON OR BEFORE:

Sat-31-May-2025

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name:

Signed:

Date:

Report Received By:

Name:

Signed:

Date:

Gas ID Number: