



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

55 Springfield Road 2025

Certificate No: 55 Springfield Road 2025

Engineers Details

Trading Title

Address
Post Code:

Gas Safe No: Telephone No:

Installation Details

Installation Address
55 Springfield Road ☐ Coventry ☐ CV1 4GR
55 Springfield Road ☐ Coventry ☐ CV1 4GR
55 Springfield Road ☐ Coventry ☐ CV1 4GR
55 Springfield Road ☐ Coventry ☐ CV1 4GR
Post Code: CV1 4GR

Telephone No:

Client Details

Client Address
Clarion Housing Group ☐
Reed House Peachman Way
Broad Business Park
Norwich
Post Code: NR7 0WF

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Airing Cupboard	Combi Boiler	Vaillant	Ecotec Pro 28	7.0	50	RS	YES	0.0007	YES	26.45 kw	YES	YES	YES	N/A	NO	YES
2																	
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: NO Gas Tightness Satisfactory: YES

Gas Installation Pipework Visual Inspection Satisfactory: NO

Number of Appliances Tested: 1 Equipotential Bonding: NO

NEXT INSPECTION DUE ON OR BEFORE: Sat-21-Feb-2026 Installation Pass: NO

CO Alarm fitted & working? NA Smoke alarm fitted & working? NA

Signatures

Report Issued By:

Name:

Report Received By:

Name:

Gas ID Number:

Signed:  Date:

Signed: Date: