



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

28 Roosevelt Drive Tile Hill
Coventry CV4 9LP

Certificate No: 28 Roosevelt Drive Tile Hill
Coventry CV4 9LP

Engineers Details

Trading Title Coventry Gas Services

Address 47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

Installation Details

Installation Address 28 Roosevelt Drive Tile Hill Coventry CV4 9LP
28 Roosevelt Drive Tile Hill Coventry CV4 9LP
Tile Hill
Coventry

Post Code: CV4 9LP

Telephone No:

Client Details

Client Address Shortland Home Property Maintenance
Warwick Gate
21-22 Warwick Row
Coventry

Post Code: CV1 1ET

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Cooker	Tecnik	Unknown	NA	NA	FL	YES	NA	YES	17 mb	NO	YES	NA	N/A	NO	NO
2	Lounge	Fire	Unknown	Unknown	NA	NA	OF	YES	NA	YES	NA mb	NO	YES	YES	N/A	NO	NO
3	Loft	Combi Boiler	Vokera	Compact 28	NA	NA	RS	YES	NA	YES	9.5 mb	YES	YES	YES	N/A	NO	YES
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1	no ep bonding on meter	advised landlord	NO
2	none of the ovens or grill work on the cooker, Tenant is lighting the cooker with a lighter which proves to be very dangerous	advised landlord	NO
3	gas fire has been capped off previous to inspection	advised landlord	NO
4			
5			

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON OR BEFORE:

Sun-18-Oct-2020

Installation Pass:

YES

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date:

Report Received By:

Name: Andrew King-Page

Signed:

Date:

Gas ID Number: 4464997