



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

310 Exhall Close Redditch B98 9JD

Certificate No: 310 Exhall Close Redditch B98 9JD

## Engineers Details

Trading Title: Coventry Gas Services

Address: 47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 526645

Telephone No: 07961768920

## Installation Details

Installation Address: 310 Exhall Close Redditch B98 9JD

310 Exhall Close Redditch B98 9JD

310 Exhall Close Redditch B98 9JD

Post Code: B98 9JD

## Client Details

Client Address: Stuart cross

4 wheatcroft close Redditch B97

Redditch

Post Code: B97 6UL

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type | Make  | Model    | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|----------------|-------|----------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Airing Cupboard | Combi Boiler   | ALPHA | Evoke 28 | 9.45            | 47               | RS                   | YES                                                              | 0.0005                               | YES                             | 27.98 kw                                     | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 2 | Kitchen         | Cooker         | Beko  | Bdg582s  | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 22 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 3 |                 |                |       |          |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |                 |                |       |          |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                |       |          |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve Accessible:

NO

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

NO

Number of Appliances Tested:

2

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON OR BEFORE:

Sat-04-Sep-2021

Installation Pass:

NO

CO Alarm fitted & working?

NA

Smoke alarm fitted & working?

NA

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date:

Gas ID Number: 4464997

Report Received By:

Name:

Signed:

Date: