

Gas Service/Breakdown Record

Certificate Ref.

16 Redcar Close 2026

Certificate No 16 Redcar Close 2026

Installation Details

Installation Address: Mr Ian Wood
16 Redcar Close
Leamington Spa
Postcode: CV327SU

Client Details

Client Address: Mr Ian Wood
16 Redcar Close
Leamington Spa
Postcode: CV327SU

Appliance Details

CO/CO2 Ratio: 0.0004 Service: YES Breakdown: N/A CO2 Reading: 8.6 % CO Reading: 34 ppm

Boiler Make: Viessmann Boiler Model: Vitodens 242-F Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 927997 Time of Arrival: 09:42 AM
Gas ID Number 5924929 Time of Departure: 09:42 AM
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Thu-19-Feb-2026
Report Received By Name: Andrew King-Page Signature: Date: Thu-19-Feb-2026