

# Gas Service/Breakdown Record

Certificate Ref.

9 Gribble Drive 2025

Certificate No 9 Gribble Drive 2025

**Installation Details**Installation  
Address:Sam SHEPHERD  
9 GRIBBLE DRIVE  
WARWICK

Postcode: CV345AS

**Client Details**Client  
Address:Sam SHEPHERD  
9 GRIBBLE DRIVE  
WARWICK

Postcode: CV345AS

**Appliance Details**CO/CO2  
Ratio:

0.0008

Service:

YES

Breakdown:

N/A

CO2

Reading:

8.5 %

CO Reading:

67 ppm

Boiler Make:

Ideal

Boiler Model:

Logic Combi ESP1 35

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

**Preliminary Checks****Satisfactory****YES****NO****NA**

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean &amp; Clear

YES

**Service Checks****Satisfactory**

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner &amp; Pilot

YES

Fuel Pressure &amp; Type

YES

**Service Operations****Satisfactory**

Burner Washed &amp; Clean

Pilot Assembly Cleaned &amp; Adjusted

Ignition System Cleaned &amp; Adjusted

Burner Fan &amp; Airways Cleaned

Heat Exchanger/Flueways Clean &amp; Clear

NA

Fuel &amp; Electrical Supply Connected &amp; Sound

YES

Interlocks in Place

**Additional Notes**

cleaned condense trap

**Spares Required**

none

**Engineers Details**

Trading Title:

Coventry Gas Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of  
Arrival:

11:32 am

Gas ID Number

5924929

Time of

Departure:

11:32 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Thu-16-Oct-2025

Report Received By

Name:

Signature:

Date:

Thu-16-Oct-2025