

Gas Service/Breakdown Record

Certificate Ref.

20 Shrerres Dyche 2025

Certificate No 20 Shrerres Dyche 202

Installation DetailsInstallation
Address:Mr A Biss
20 Shrerres Dyche
Warwick

Postcode: CV34 6BX

Client DetailsClient
Address:Mr A Biss
20 Shrerres Dyche
Warwick

Postcode: CV34 6BX

Appliance DetailsCO/CO2
Ratio:

0.0004

Service:

0.0004

Breakdown:

N/A

CO2

Reading:

9.5 %

CO Reading:

35 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 24 RI HE

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution		YES		
Ventilation Size/H-L		YES		
Water/Fuel - Sound		YES		
Electrically Fused		YES		
Correct Valving Arrangement		YES		
Isolation Available - Electrical/Fuel (Within 1 metre)		YES		
Boiler/Plant room Clean & Clear		YES		
Service Checks	Satisfactory			
Heat Exchanger		YES		
Ignition		YES		
Gas Valve		YES		
Fan		YES		
Safety Device		YES		
Control Box		YES		
Burner & Pilot		YES		
Fuel Pressure & Type		YES		
Service Operations	Satisfactory			
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound		YES		
Interlocks in Place				

Additional Notes

serviced boiler

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

09:39 am

Gas ID Number

5739462

Time of

Departure:

09:39 am

Telephone Number

07961768920

Report Issued By

Name: Andrew King-Page

Signature:



Date:

Tue-29-Jul-2025

Report Received By

Name:

Signature:

Date:

Tue-29-Jul-2025