

# Gas Service/Breakdown Record

Certificate Ref.

46 Newbold Terrace East 2025

Certificate No 46 Newbold Terrace E

**Installation Details**Installation  
Address:Oliver Danker  
46 Newbold Terrace East  
Leamington Spa

Postcode: Cv32 4EZ

**Client Details**Client  
Address:Oliver Danker  
46 Newbold Terrace East  
Leamington Spa

Postcode: Cv32 4EZ

**Appliance Details**CO/CO2  
Ratio:

0.0007

Service:

YES

Breakdown:

N/A

CO2

Reading:

7.2 %

CO Reading:

53 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 8000 Life

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

**Preliminary Checks****Satisfactory**

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean &amp; Clear

YES

**Service Checks****Satisfactory**

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner &amp; Pilot

YES

Fuel Pressure &amp; Type

YES

**Service Operations****Satisfactory**

Burner Washed &amp; Clean

Pilot Assembly Cleaned &amp; Adjusted

Ignition System Cleaned &amp; Adjusted

Burner Fan &amp; Airways Cleaned

Heat Exchanger/Flueways Clean &amp; Clear

NA

Fuel &amp; Electrical Supply Connected &amp; Sound

YES

Interlocks in Place

**Additional Notes**

cleaned filter and condense trap

**Spares Required**

none

**Engineers Details**

Trading Title:

Coventry Gas Services Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of  
Arrival:

10:19 am

Gas ID Number

5739462

Time of

Departure:

10:19 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Fri-21-Feb-2025

Report Received By

Name:

Signature:

Date:

Fri-21-Feb-2025