

Gas Service/Breakdown Record

Certificate Ref.

21 Tenbury Close 2025

Certificate No 21 Tenbury Close 202

Installation Details

Installation Address: Michael Rippington
21 Tenbury Close
Redditch

Postcode: B98 9LB

Client Details

Client Address: Michael Rippington
21 Tenbury Close
Redditch

Postcode: B98 9LB

Appliance DetailsCO/CO2
Ratio:

0.0004

Service:

YES

Breakdown:

N/A

CO2

Reading:

7.9 %

CO Reading:

28 ppm

Boiler Make: Potterton Boiler Model: Titanium 24 Combi Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks**Satisfactory****YES****NO****NA**

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks**Satisfactory**

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations**Satisfactory**

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

serviced boiler, cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

10:43 am

Gas ID Number

5739462

Time of

Departure:

10:43 am

Telephone Number

07961768920

Report Issued By Name: Andrew King-Page

Signature:

Date:

Mon-17-Feb-2025

Report Received By Name: Andrew King-Page

Signature:

Date:

Mon-17-Feb-2025