



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

580 Broad Lane 2025

Certificate No: 580 Broad Lane 2025

## Engineers Details

Trading Title  
Coventry Gas Ltd

Address  
47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation  
Address

580 Broad Lane Coventry CV5 7BT  
580 Broad Lane Coventry CV5 7BT  
580 Broad Lane Coventry CV5 7BT  
580 Broad Lane Coventry CV5 7BT

Post Code: CV5 7BT

Telephone No:

## Client Details

Client  
Address

Iain Black  
578 Broad Lane  
Coventry

Post Code: CV5 7BT

Telephone No: 07951735561

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type | Make     | Model                | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|----------------|----------|----------------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Airing Cupboard | Combi Boiler   | Baxi     | Duo Tec 24 Combi Erp | 8.5             | 39               | RS                   | YES                                                              | 0.0005                               | YES                             | 23.38 kw                                     | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 2 | Kitchen         | Cooker         | Hotpoint | Cucina HAG51K        | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 18 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 3 |                 |                |          |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |                 |                |          |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                |          |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |                                   |                  |    |
|---|-----------------------------------|------------------|----|
| 1 | no ep bonding on meter            | advised landlord | NO |
| 2 | gas pipe not sleeved through wall | advised landlord | NO |
| 3 | gas meter box door broken         | advised landlord | NO |
| 4 |                                   |                  |    |
| 5 |                                   |                  |    |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

NO

Number of Appliances Tested:

2

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON OR BEFORE:

Sun-22-Nov-2026

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Thu-13-Nov-2025

Report Received By:

Name:

Signed:

Date: Thu-13-Nov-2025

Gas ID Number: 5924929