



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

4 Wheatcroft Close 2025 1

Certificate No: 4 Wheatcroft Close 2025 1

## Engineers Details

Trading Title Coventry Gas Ltd

Address 47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation Address

Stuart cross  
4 wheatcroft close □ Redditch □ B97  
Redditch

Post Code: B97 6UL

## Client Details

Client Address

Stuart cross  
4 wheatcroft close □ Redditch □ B97  
Redditch

Post Code: B97 6UL

## Appliance Details

## Inspection Details

|   | Location | Appliance Type | Make        | Model                | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure (mbar) or Heat Input (kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|----------|----------------|-------------|----------------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|----------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Kitchen  | Combi Boiler   | ALPHA       | E Tec Plus 38        | 8.7             | 126              | RS                   | YES                                                              | 0.0015                               | YES                             | 37.28 kw                                     | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 2 | Kitchen  | Hob            | Whirlpool   | Unknown              | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 22 mb                                        | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 3 | Lounge   | Fire           | Focal Point | AG 125/3AR MULTIPOIN | NA              | NA               | OF                   | YES                                                              | NA                                   | YES                             | 5.87 kw                                      | YES                                            | YES                                         | YES                                                               | PASS                                 | NO                             | YES                            |
| 4 |          |                |             |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |          |                |             |                      |                 |                  |                      |                                                                  |                                      |                                 |                                              |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Fri-02-Oct-2026

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Thu-02-Oct-2025

Report Received By:

Name:

Signed:

Date: Thu-02-Oct-2025

Gas ID Number: 5924929