



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

55 The Cornfield CV3 1FD

Certificate No: 55 The Cornfield CV3 1FD

Engineers Details

Trading Title
Coventry Gas Ltd

Address
47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

Installation Details

Installation
Address

55 The Cornfield CV3 1FD
55 The Cornfield CV3 1FD
55 The Cornfield CV3 1FD
55 The Cornfield CV3 1FD

Post Code:

Client Details

Client
Address

Citizen Housing Group Ltd
Lakeside
4040 Solihull Pkwy,
Birmingham

Post Code: B37 7YN

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1																	
2																	
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1	no gas at property, gas central heating but no gas meter	none	NO
2			
3			
4			
5			

Emergency Control Valve
Accessible:

NO

Gas Tightness Satisfactory:

NA

Gas Installation Pipework Visual Inspection Satisfactory:

NO

Number of Appliances Tested:

0

Equipotential Bonding:

NO

NEXT INSPECTION DUE ON
OR BEFORE:

Fri-02-Oct-2026

Installation Pass:

NO

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Thu-02-Oct-2025

Report Received By:

Name:

Signed:

Date: Thu-02-Oct-2025

Gas ID Number: 5924929