



WARNING NOTICE - DANGER DO NOT USE

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure

Certificate No.

10 LUFF CLOSE CV3 1DE

Registered Business Details

Coventry Gas Services Ltd

47 Alspath Road

Meriden

07961768920

Postcode: CV7 7LU

Installation Details

Martin Fisher

10 LUFF CLOSE, CV3 1DE

10 LUFF CLOSE, CV3 1DE

10 LUFF CLOSE, CV3 1DE

Postcode:

Client Details

Citizen Housing Group Ltd

Lakeside

4040 Solihull Pkwy,

Birmingham

07763264485

Postcode: B37 7YN

1. THE GAS APPLIANCE / GAS INSTALLATION

Make: Statesman

Model: Unknown

Type: Cooker

Serial No: 00616198003510620091

Installation Details: (e.g. gas pipework, gas meter) gas cooker leaking gas

Fixed in the room / location: (if known) Kitchen

2. IS UNSAFE AND HAS BEEN CATEGORISED IMMEDIATELY DANGEROUS (ID) because:

- ☒ YES A gas escape has been detected on the appliance / installation or
- ☒ YES gas cooker leaking gas and
- ☒ YES with your permission it has been disconnected from the gas supply and a DANGER DO NOT USE label attached or,
- ☐ NA as you have refused to allow it to be made safe, a DANGER DO NOT USE label has been attached*

Gas Emergency Contact Centre Reference: _____

4. RIDDOR:

☐ The unsafe situation(s) identified is reportable to the Health and Safety Executive (HSE) under RIDDOR

5. REMEDIAL ACTION REQUIRED:

FOR YOUR OWN SAFETY 'IMMEDIATELY DANGEROUS' & 'AT RISK' GAS APPLIANCES / INSTALLATIONS SHOULD NOT BE USED

Gas User/Responsible Person Declaration: I confirm that I have received this Warning Notice concerning the safety of the gas installation. I understand that the use of the appliance/installation in case of an **IMMEDIATELY DANGEROUS** or **AT RISK** installation, could present a danger and could place me in breach of the Gas Safety (Installation and Use) Regulations.

Signed:  Print Name: Martin Fisher

Date: Thu-10-Apr-2025

The gas user was not present at the time of visit, the installation has been made safe and this notice left on the premises.

☒ YES

Gas Operative Declaration: I confirm that the situation(s) recorded above, has been identified and brought to the attention of the Gas User/Responsible Person in accordance with the Gas Safety (Installation and Use) Regulations (GSIUR), Industry Standards and Procedures.

Licence No: 5739462 927997

Signed:  Print Name: Andrew King-Page

Issue Date: Thu-10-Apr-2025 Issue Time: 11:09 am