

Gas Service/Breakdown Record

Certificate Ref.

5 exmore drive 2026

Certificate No 5 exmore drive 2026

Installation Details

Installation Address: Peter Maxwell
5 exmore drive
Leamington Spa

Postcode: CV32 7BB

Client Details

Client Address: Peter Maxwell
5 exmore drive
Leamington Spa

Postcode: CV32 7BB

Appliance Details

CO/CO2 Ratio:

0.0009

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.9 %

CO Reading:

91 ppm

Boiler Make: Worcester

Boiler Model: Greenstar 30i Erp

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of Arrival:

08:58 AM

Gas ID Number

5924929

Time of Departure:

08:58 AM

Telephone Number

07961768920

Report Issued By Name:

Andrew King-Page

Signature:



Date:

Tue-10-Mar-2026

Report Received By Name:

Andrew King-Page

Signature:



Date:

Tue-10-Mar-2026