

Gas Service/Breakdown Record

Certificate Ref.

Our lady of sacred heart 2026 Church

Certificate No Our lady of sacred heart

Installation Details		Client Details																																					
Installation Address:	Our Lady Of The Sacred Heart Mill Ln Bulkington Bedworth Postcode: CV12 9RU	Client Address:	Our Lady Of The Sacred Heart Mill Ln Bulkington Bedworth Postcode: CV12 9RU																																				
Appliance Details CO/CO2 Ratio: 0.0010 Service: YES Breakdown: N/A CO2 Reading: 8.3 % CO Reading: 89 ppm																																							
Boiler Make:	Baxi	Boiler Model:	830 System																																				
Boiler Serial No:																																							
Appliance Make:		Appliance Model:																																					
Appliance Serial No:																																							
Preliminary Checks <table border="1"> <thead> <tr> <th>Satisfactory</th> <th>YES</th> <th>NO</th> <th>NA</th> </tr> </thead> <tbody> <tr><td>Flue:Atmospheric/Fan assisted/Fan Dilution</td><td>YES</td><td></td><td></td></tr> <tr><td>Ventilation Size/H-L</td><td>YES</td><td></td><td></td></tr> <tr><td>Water/Fuel - Sound</td><td>YES</td><td></td><td></td></tr> <tr><td>Electrically Fused</td><td>YES</td><td></td><td></td></tr> <tr><td>Correct Valving Arrangement</td><td>YES</td><td></td><td></td></tr> <tr><td>Isolation Available - Electrical/Fuel (Within 1 metre)</td><td>YES</td><td></td><td></td></tr> <tr><td>Boiler/Plant room Clean & Clear</td><td>YES</td><td></td><td></td></tr> </tbody> </table>		Satisfactory	YES	NO	NA	Flue:Atmospheric/Fan assisted/Fan Dilution	YES			Ventilation Size/H-L	YES			Water/Fuel - Sound	YES			Electrically Fused	YES			Correct Valving Arrangement	YES			Isolation Available - Electrical/Fuel (Within 1 metre)	YES			Boiler/Plant room Clean & Clear	YES			Additional Notes cleaned condense trap and filter					
Satisfactory	YES	NO	NA																																				
Flue:Atmospheric/Fan assisted/Fan Dilution	YES																																						
Ventilation Size/H-L	YES																																						
Water/Fuel - Sound	YES																																						
Electrically Fused	YES																																						
Correct Valving Arrangement	YES																																						
Isolation Available - Electrical/Fuel (Within 1 metre)	YES																																						
Boiler/Plant room Clean & Clear	YES																																						
Service Checks <table border="1"> <thead> <tr> <th>Satisfactory</th> <th>YES</th> <th>NO</th> <th>NA</th> </tr> </thead> <tbody> <tr><td>Heat Exchanger</td><td>YES</td><td></td><td></td></tr> <tr><td>Ignition</td><td>YES</td><td></td><td></td></tr> <tr><td>Gas Valve</td><td>YES</td><td></td><td></td></tr> <tr><td>Fan</td><td>YES</td><td></td><td></td></tr> <tr><td>Safety Device</td><td>YES</td><td></td><td></td></tr> <tr><td>Control Box</td><td>YES</td><td></td><td></td></tr> <tr><td>Burner & Pilot</td><td>YES</td><td></td><td></td></tr> <tr><td>Fuel Pressure & Type</td><td>YES</td><td></td><td></td></tr> </tbody> </table>		Satisfactory	YES	NO	NA	Heat Exchanger	YES			Ignition	YES			Gas Valve	YES			Fan	YES			Safety Device	YES			Control Box	YES			Burner & Pilot	YES			Fuel Pressure & Type	YES			Spares Required none	
Satisfactory	YES	NO	NA																																				
Heat Exchanger	YES																																						
Ignition	YES																																						
Gas Valve	YES																																						
Fan	YES																																						
Safety Device	YES																																						
Control Box	YES																																						
Burner & Pilot	YES																																						
Fuel Pressure & Type	YES																																						
Service Operations <table border="1"> <thead> <tr> <th>Satisfactory</th> <th>YES</th> <th>NO</th> <th>NA</th> </tr> </thead> <tbody> <tr><td>Burner Washed & Clean</td><td></td><td></td><td></td></tr> <tr><td>Pilot Assembly Cleaned & Adjusted</td><td></td><td></td><td></td></tr> <tr><td>Ignition System Cleaned & Adjusted</td><td></td><td></td><td></td></tr> <tr><td>Burner Fan & Airways Cleaned</td><td></td><td></td><td></td></tr> <tr><td>Heat Exchanger/Flueways Clean & Clear</td><td></td><td></td><td>NA</td></tr> <tr><td>Fuel & Electrical Supply Connected & Sound</td><td>YES</td><td></td><td></td></tr> <tr><td>Interlocks in Place</td><td></td><td></td><td></td></tr> </tbody> </table>		Satisfactory	YES	NO	NA	Burner Washed & Clean				Pilot Assembly Cleaned & Adjusted				Ignition System Cleaned & Adjusted				Burner Fan & Airways Cleaned				Heat Exchanger/Flueways Clean & Clear			NA	Fuel & Electrical Supply Connected & Sound	YES			Interlocks in Place									
Satisfactory	YES	NO	NA																																				
Burner Washed & Clean																																							
Pilot Assembly Cleaned & Adjusted																																							
Ignition System Cleaned & Adjusted																																							
Burner Fan & Airways Cleaned																																							
Heat Exchanger/Flueways Clean & Clear			NA																																				
Fuel & Electrical Supply Connected & Sound	YES																																						
Interlocks in Place																																							
Engineers Details Trading Title: Coventry Gas Ltd 47 Alspath Road Meriden Postcode: CV7 7LU		Gas Safe Number 927997 Time of Arrival: 01:28 PM Gas ID Number 5924929 Time of Departure: 01:28 PM Telephone Number 07961768920																																					
Report Issued By Name:	Andrew King-Page	Signature:	Signature																																				
Report Received By Name:		Signature:																																					
Date:	Thu-26-Feb-2026																																						
Date:	Thu-26-Feb-2026																																						