

Gas Service/Breakdown Record

Certificate Ref.

20 Kings Road 2026

Certificate No 20 Kings Road 2026

Installation Details

Installation Address: 20 Kings Road Stockland Green Birmingham B23 7JS
20 Kings Road Stockland Green Birmingham B23 7JS
20 Kings Road Stockland Green Birmingham B23 7JS
20 Kings Road Stockland Green Birmingham B23 7JS
Postcode:

Client Details

Client Address: Bal Forwell
44 Glendon Road
Birmingham
West Midlands
Postcode: B23 5HG

Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: N/A CO2 Reading: 9.5 % CO Reading: 45 ppm

Boiler Make: Ideal Boiler Model: ISAR HE30 Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory YES NO NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

cleaned condense trap and filter

Spares Required

needs new hot water turbine

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 927997 Time of Arrival: 10:32 AM
Gas ID Number 5924929 Time of Departure: 10:32 AM
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Thu-12-Feb-2026
Report Received By Name: Signature: Date: Thu-12-Feb-2026