

Gas Service/Breakdown Record

Certificate Ref.

12 barbel drive-Chai Go, Young-02

Certificate No 12 barbel drive

Installation Details

Installation Address: Chai Go, Young
12 Barbel Drive,
Blythe Valley
Solihull

Postcode: B90 8DR

Client Details

Client Address: Chai Go, Young
12 Barbel Drive,
Blythe Valley
Solihull

Postcode: B90 8DR

Appliance DetailsCO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.5 %

CO Reading:

47 ppm

Boiler Make:

Ideal

Boiler Model:

Logic Code ESPI 38

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory			
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory			
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

08:58 am

Gas ID Number

5545563

Time of

Departure:

08:58 am

Telephone Number

07961768920

Report Issued By

Name: Andrew King-Page

Signature:



Date:

Wed-02-Jul-2025

Report Received By

Name:

Signature:

Date:

Wed-02-Jul-2025